

Notes:

1. When you update control panel to V1.2.8, please also update your LCD Keypad (DS-PK1-LT-WE) to V1.0.3, LED Keypad (DS-PK1-E-WE) to V1.7.0 and Relay Module to V1.4.0.

For LED Keypad supports remote upgrade only when the version is higher than V1.1.256.

For Relay Module supports remote upgrade only when the version is higher than V1.1.0.

2. We support wired detectors connected to Tri EOL or Dual Zone EOL in V1.2.8 version. If you have wired detectors in your system, please change the wiring of the detectors before upgrading to V1.2.8, otherwise the alarm system will be wrong. If you do not have a wired detector connected to your system, you can upgrade directly.